



Reference no. HAR-NL: 1800-075

# Licence

to use the harmonization marking



Name: Kabelbedrijven Draka Nederland B.V.  
Address: Hamerstraat 2-4, 1021 JV Amsterdam, The Netherlands  
Factory: Emmen and Amsterdam, The Netherlands

has been granted the right to use the harmonization marking consisting of:  
either the mark

**KEMA-KEUR**



or a black-red-yellow coloured thread i.e. 1 cm black, 3 cm red and 3 cm yellow for the product listed below, which is tested and found complying to HD 22.4 S4:2004; clause 5 as stated in test report no. 2115837.03

**Product data:**

Product type Heavy PCP or other equivalent synthetic elastomer sheathed flexible cable  
Code designation H07RN-F  
Rated voltage 450/750V  
Indication of origin DRAKA, DRAKAFLEX or textile thread black/red (00/20)

This Licence supersedes Licence HAR-NL 1800-056, dated February 10, 2006

This licence is issued according to the rules of the HAR Agreement, wherein the licence issued by any certification body adhering to the HAR Agreement has the same worth and validity in all the other certification bodies' countries.

KEMA Quality B.V.

Arnhem, 9 April 2008

H.R.M. Barends

Note: The black-red-yellow thread has been registered in the Netherlands as a certification Trade Mark for Verband Deutscher Elektotechniker (VDE). VDE has authorized KEMA to use this thread.

**KEMA Quality B.V.**

Utrechtseweg 310, 6812 AR Arnhem  
P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22

ACCREDITED BY  
THE DUTCH  
COUNCIL FOR  
ACCREDITATION



<http://buvniecibas-abc.lv/deklaracijas>

**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product : Heavy PCP or other equivalent synthetic elastomer sheathed flexible cable  
trade name : DRAKA KABEL  
types : H07RN-F  
rated voltage : 450/750V  
certified cables : 1 x 1,5-630 mm<sup>2</sup>, 2 x 1-25 mm<sup>2</sup>, 3 x 1-300 mm<sup>2</sup>, 4 x 1-300 mm<sup>2</sup> and 5 x 1-25 mm<sup>2</sup>

**Tests****Test requirements**

HD 22.4 S4:2004; clause 5

**Test result**

The test results are laid down in KEMA test file 2115837.03

**Remarks**

This HAR-licence is based on and supersedes KEMA test file 2089408.03 including HAR-licence HAR-NL 1800-056, dated February 10, 2006.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : A.A. Mackenbach

Checked by : H.R.M. Barends **Factory-Location(s)**

Kabelbedrijven Draka Nederland B.V.  
Hamerstraat 2-4  
1021 JV Amsterdam, The Netherlands

Kabelbedrijven Draka Nederland B.V.  
Abel Tasmanstraat 1  
7821 AN Emmen, The Netherlands

**KEMA Quality B.V.**

Utrechtseweg 310, 6812 AR Arnhem  
P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22

ACCREDITED BY  
THE DUTCH  
COUNCIL FOR  
ACCREDITATION

